

## **ADDENDUM NO. 1**

**NAME: Request for Proposals for Alarm Services- Town wide- TNH046-2016**

**DATE: March 18, 2016**

**TO: All Prospective Proposers**

This amendment is being issued to inform the following:

- 1- In the specifications it is calling for inspections/monitoring of the CCTV system at the Gold Coast Arts Center, there is no information/equipment list posted?

Is that information available?

What are the FA device counts for these locations:

Harbor Links: Executive and Maintenance

Manorhaven Beach Park

Roslyn Community Center

Clinton G. Martin Park

Town Hall II

Animal Shelter

Gold Coast Arts Center

**The information requested here is being compiled and will be made available shortly.**

- 2- Are the beam detectors at the Yes We Can Community Center accessible with a ladder? **No, a lift would be needed.**

- 3- In regards to bid #TNH046-2016 Alarm Services. I spoke with Maria Gomes today

It appears that the vendor has the ability to choose the location to bid on. So it is the understanding, that different locations can be chosen for a vendors bid response. I have a couple of questions:

- a. Since certain types of Fire Alarm Systems utilize a proprietary software code, will that code be made available to the vendor? This may be needed to change addressable devices on your Edwards EST systems. (New Your Fire Service is a Strategic Partner with Edwards fire systems) **All software needed to operate the systems will be provided or otherwise made available.**
- b. Many companies specialize in Fire or Security due to the specialization required in complicated fire systems. Would it be possible to bid on a location for Fire or Burglar only? **Yes, vendors may bid only on fire or burglar systems. However, as stated in the bid documents, if a vendor submits a bid for a particular system, that vendor must supply inspections, monitoring and repairs.**

- 4- We are the building fire alarm vendor for North Hempstead community Center and show the address as 141 Garden St. The bid package mentions Yes We Can community Center at 149 Garden St. Are these both the same structure? **Yes.**

The "ADDENDUM NO. 1 RECEIPT ACKNOWLEDGEMENT FORM" on the last page of this Addendum NO. 1 must be signed and dated in the spaces provided and submitted with your Proposal. All Proposers must submit this form with its Proposal regardless of the content contained in each Addendum.

## ADDENDUM NO.1 RECEIPT ACKNOWLEDGEMENT FORM

### REQUEST FOR PROPOSALS FOR – Alarm Services- Town wide

By signing this Acknowledgement and submitting same with its Proposal submission, the undersigned Proposer acknowledges receipt of this Addendum No. 1. Proposer further acknowledges that it has read and reviewed the information contained herein, understands same, and that its questions, if any presented, have been answered satisfactorily. Proposer agrees that it shall incorporate/consider the information contained in this Addendum No. 1 in preparing and providing its proposal price. In addition, this Addendum No.1 Receipt Acknowledgement Form must be signed and dated and attached to the proposal submittal.

Signature: \_\_\_\_\_

Company Name: \_\_\_\_\_

Proposer Acknowledgement Date: \_\_\_\_\_

Print & Sign Company Principal Name & Title: \_\_\_\_\_

\_\_\_\_\_