

ADDENDUM NO. 3

NAME: Bid for Alarm Services - Townwide - RFP No. TNH 046-2016

DATE: March 29, 2016

TO: All Prospective Proposers

In response to questions asked of the Town in regard to the bid:

- 1. Q. In the specifications, it is calling for inspections/monitoring of the CCTV system at the Gold Coast Arts Center, there is no information/equipment list posted?**

What are the FA device counts for these locations?

Harbor Links: Executive and Maintenance
Manorhaven Beach Park
Roslyn Community Center
Clinton G. Martin Park
Town Hall II
Animal Shelter
Gold Coast Arts Center

A. Harbor Links: Executive

Pull Stations: 7
Smoke Detectors: 10
Strobes: 8
Heat Detectors: 2

Harbor Links: Maintenance

Pull Stations: 7
Smoke Detectors: 3
Strobes: 6
Heat Detectors: 1

Roslyn Community Center

79 Individual Sprinkler Heads

Clinton G. Martin Park

Sprinklers: 93
Smoke Detectors: 11
Alarm Pull Boxes: 3
Bells with Strobes: 3
CO2 Detectors: 3

Town Hall II

5 Panic Buttons

Animal Shelter

See Attached listing

Gold Coast Arts Center

Fire Alarm Control Panel	Spectronics	1
Manual Pull Station	Spectronics	3
smoke detector	Spectronics	60
heat detector	Spectronics	4
heat detector	Chemetronics	1
monitor modules	Spectronics	6
isolator modules	Spectronics	4
control modules	Spectronics	8
relays	Space Age	4
horn/strobes	Gentex	10
strobes	Gentex	13
sync module	Gentex	2
remote LED indicators	System Sensor	23
remote annunciator	D&S Technologies	1

Manorhaven Beach Park

- 1 Fire Alarm Control Panel
- 1 Remote Annunciator
- 8 Multipurpose Piping Systems
- 49 Smoke Detectors
- 10 Heat sensors
- 2 Data Gathering Panels
- 1 Sprinkler Bell
- 18 Heat Detectors
- 4 Fans
- 14 Strobes
- 3 Tamper Switches

The "ADDENDUM NO. 3 RECEIPT ACKNOWLEDGEMENT FORM" on the last page of this Addendum No. 3 must be signed and dated in the spaces provided and submitted with your Bid. All Bidders must submit this form with its Bid regardless of the content contained in each Addendum.

ADDENDUM NO.3 RECEIPT ACKNOWLEDGEMENT FORM

BID FOR ALARM SERVICES - TOWNWIDE – RFP No. TNH046-2016

By signing this Acknowledgement and submitting same with its Bid submission, the undersigned Bidder acknowledges receipt of this Addendum No. 3. Bidder further acknowledges that it has read and reviewed the information contained herein, understands same, and that its questions, if any presented, have been answered satisfactorily. Bidder agrees that it shall incorporate/consider the information contained in this Addendum No. 3 in preparing and providing its bid price. In addition, this Addendum No. 3 Receipt Acknowledgement Form must be signed and dated and attached to the bid submittal.

Signature: _____

Company Name: _____

Bidder Acknowledgement Date: _____

Print & Sign Company Principal Name & Title: _____

Animal Shelter Devices:

FIRE ALARM SYMBOL LEGEND -- NEW DEVICES					
SYMBOL	DESCRIPTION	MANUFACT.	MODEL NUMBER	ADDITIONAL PARTS	QUANTITY
FACP	FIRE ALARM CONTROL PANEL	SILENT KNIGHT	SK-5208	SEE BATTERY CALCS FOR PANEL COMPONENTS	1
RAI	REMOTE ANNUNCIATOR	SILENT KNIGHT	SK-5235	NONE	1
MPR	MANUAL FAN RESTART	AIR PRODUCTS AND CONTROLS	MR-101/C/R	N.O. MOMENTARY PUSH BUTTON	1
S	SMOKE DETECTOR	SYSTEM SENSOR	2W-B	NONE	29
SA	SMOKE DETECTOR -- ABOVE CEILING	SYSTEM SENSOR	2W-B	NONE	31
F	MANUAL FIRE ALARM PULL STATION	SILENT KNIGHT	PS-SA	SB-10 (OPT)	7
H	HEAT DETECTOR	EST	283B-PL	NONE	3
HW	HEAT DETECTOR -- WEATHERPROOF	EST	302-ET-135	AP-P (REQ)	11
RE	REMOTE ALARM INDICATOR LAMP	SYSTEM SENSOR	RA100Z	NONE	31
R	RELAY (MULTI-VOLTAGE)	AIR PRODUCTS AND CONTROLS	MR-101/C/R	NONE	2
H	HORN STROBE (CANDELA SPECIFIED ON FLOOR PLAN)	SYSTEM SENSOR	P2R	BBS-2 (OPT)	6
WP AV	HORN STROBE -- CEILING MOUNT & WEATHERPROOF	SYSTEM SENSOR	PC2RK	BBSC-2 (OPT)	6
AV	HORN STROBE -- CEILING MOUNT (CANDELA SPECIFIED ON FLOOR PLAN)	SYSTEM SENSOR	PC2R	BBSC-2 (OPT)	3
S	STROBE (CANDELA SPECIFIED ON FLOOR PLAN)	SYSTEM SENSOR	SR	BBS-2 (OPT)	7
MS	HVAC MOTOR STARTER LOCATION (UNIT SHUTDOWN UPON ALARM)	FURNISHED & INSTALLED BY OTHERS			2

Total 141