

ADDENDUM NO. 2

NAME: SWMA004-2020-Replacement of Roll –Up Doors at North Hempstead Transfer Station

DATE: August 17, 2020

TO: All Prospective Proposers

1. What is the Steel Door-Spring cycle?

The doors are opened at the beginning of the day and are closed at the end of the day. Otherwise the doors will be closed as needed. The Transfer Station is open 6 days a week and approximately 5 weeks out of the year opened 7 days a week. Please submit a door with a spring cycle that corresponds with that usage.

2. What type of door for the Truck Tunnel?

This information is stated in the Request for Sealed Bids under Section C2. Tunnel.

3. Will The Authority consider mounting doors on the exterior face of the building?

The Authority will keep the doors as currently configured.

4. What is the Transfer Station power to the doors?

480 volts 3 phase

5. Warranty with the installation?

The successful proposer must provide a maintenance bond with a term of at least one year. Section 62 of the terms and conditions describe the required warranties.

6. Will The Authority consider using Rubber Doors?

The high speed door model examples stated in the bid are rubber doors. The Authority has a preference for rubber doors over fabric door for the high speed door installations.

The “ADDENDUM NO. 2 RECEIPT ACKNOWLEDGEMENT FORM” on the last page of this Addendum NO. 2 must be signed and dated in the spaces provided and submitted with your Proposal. All Proposers must submit this form with its Proposal regardless of the content contained in each Addendum

ADDENDUM NO.2 RECEIPT ACKNOWLEDGEMENT FORM

SWMA004-2020-Replacement of Roll –Up Doors at North Hempstead Transfer Station

By signing this Acknowledgement and submitting same with its Proposal submission, the undersigned Proposer acknowledges receipt of this Addendum No. 2. Proposer further acknowledges that it has read and reviewed the information contained herein, understands same, and that its questions, if any presented, have been answered satisfactorily. Proposer agrees that it shall incorporate/consider the information contained in this Addendum No. 2 in preparing and providing its proposal price. In addition, this Addendum No.2 Receipt Acknowledgement Form must be signed and dated and attached to the proposal submittal.

Signature: _____

Company Name: _____

Proposer Acknowledgement Date: _____

Print & Sign Company Principal Name & Title: _____
